

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

BR = Bathroom Sink

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

SP - Outside spigot

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 9/29/2016

Building Name: VanBuren Elementary School

Total No. Samples: 49

Sample No.	Description	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Re-test on Jan 13, 2107 Lead Conc. (ppb)	Re-test on Jan 28, 2107 Lead Conc. (ppb)
VB1	First Draw	6:09am	Rm 101	CF		6.8		
VB2	First Draw	6:10am	Rm 102	CF		10.0		
VB3	First Draw	6:11am	Rm 103	CF		24.0	17	15
VB4	First Draw	6:12am	Rm 103	BR		13.0		
VB5	First Draw	6:12am	Rm 104	CF		18.0		12
VB6	First Draw	6:13am	Rm 104	BR		9.7		
VB7	First Draw	6:14am	Rm 105	CF		15.0		9.8
VB8	First Draw	6:15am	Rm 105	BR		6.8		
VB9	First Draw	6:15am	Rm 106	CF		4.6		
VB10	First Draw	6:16am	Rm 106	BR		1.6		
VB11	First Draw	6:17am	Rm 107	CF		12.0		
VB12	First Draw	6:17am	Rm 107	BR		11.0		
VB13	First Draw	6:19am	Rm 108	CF		15.0		3.6
VB14	First Draw	6:19am	Rm 108	BR		5.8		
VB15	First Draw	6:21am	Rm 111 -Nurse	NS		4.6		
VB16	First Draw	6:24am	Rm 117	BR		9.8		
VB17	First Draw	6:25am	Rm 119-A	BR		30.0		24
VB18	First Draw	6:25am	Rm 119-B	BR		8.7		
VB19	First Draw	6:25am	Rm 119-C	BR		4.7		
VB20	First Draw	6:26am	Rm 119-D	BR		7.1		
VB21	First Draw	6:26am	Rm 119-E	BR		7.9		
VB22	First Draw	6:28am	Rm 123-A	BR		12.0		
VB23	First Draw	6:28am	Rm 123-B	BR		3.1		
VB24	First Draw	6:29am	Rm 123-C	BR		4.5		
VB25	First Draw	6:29am	Rm 123-D	BR		5.1		
VB26	First Draw	6:29am	Rm 123-E	BR		9.3		

Sample No.	Description	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Re-test on Jan 13, 2107 Lead Conc. (ppb)	Re-test on Jan 28, 2107 Lead Conc. (ppb)
VB27	First Draw	6:30am	RM125	CF		68.0		16
VB28	First Draw	6:31am	Rm 126	CF		17.0	14	12
VB29	First Draw	6:34am	Rm 127	CF		32.0		20
VB30	First Draw	6:35am	Rm 128	CF		10.0		
VB31	First Draw	6:35am	Rm 129	CF		45.0		34
VB32	First Draw	6:36am	Rm 130	CF		14.0		
VB33	First Draw	6:37am	Rm 135-A	BR		3.0		
VB34	First Draw	6:37am	Rm 135-B	BR		1.5		
VB35	First Draw	6:37am	Rm 135-C	BR		1.9		
VB36	First Draw	6:39am	Rm139-A	BR		3.0		
VB37	First Draw	6:39am	Rm 139-B	BR		1.5		
VB38	First Draw	6:39am	Rm 139-C	BR		2.2		
VB39	First Draw	6:41am	Rm 141	CF		10.0		
VB40	First Draw	6:42am	Rm 142	CF		12.0		
VB41	First Draw	6:43am	Rm 144	CF		18.0		54
VB42	First Draw	6:44am	Rm 146	CF		34.0		56
VB43	First Draw	6:45am	Rm 148	CF		85.0	22	93
VB44	First Draw	6:46am	RM 145	CF		29.0		14
VB45	First Draw	6:47am	Rm 147	CF		52.0		26
VB46	First Draw	6:47am	Rm 150	CF		38.0		82
VB47	First Draw	6:48am	Rm 151	CF		66.0	3	24
VB48	First Draw	6:49am	Rm 152	CF		58.0		20
VB49	First Draw	6:50am	Rm 153	CF		23.0		24
VBext8	First Draw	7:11am	spigot exit 8	SP			6	
VB019-ice	First Draw	8:34am	Nurse Ice Mach					1200

*** Note 1 - Faucet aerators replaced for follow up re-testing