

## Drinking water Sampling and Analysis for Lead (Pb)

### Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 3/11/2016

Building Name: Baker High School

Total No. Samples: **66**

Sample No	Description	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
1	First Flush	3/11/16-5:15:00 AM	Nurse Off. Back sink	DF		3.0
1a	30 sec. draw	5:16	"	"		2.0
2	First Flush	5:17	Nurse Off. Fr. Sink	"		2.2
2a	30 sec. draw	5:18	"	"		2.6
3	First Flush	5:19	Hallway nr. G208	"		1.4
3a	30 sec. draw	5:20	"	"		1.5
4	First Flush	5:22	Café' 1	"		1.2
4a	30 sec. draw	5:23	"	"		1.2
5	First Flush	5:25	Café' 3	"		BDL
5a	30 sec. draw	5:26	"	"		1.2
6	First Flush	5:27	Boys N Lckr. Rm.	"		4.1
6a	30 sec. draw	5:28	"	"		1.5
7	First Flush	5:31	Girl's Lckr Rm.	"		3.9
7a	30 sec. draw	5:32	"	"		BDL
8	First Flush	5:32	Kitchen Soup Spigot	"		2.5
8a	30 sec. draw	5:33	"	"		BDL
9	First Flush	5:36	Kitchen Sink Ctr.	"		BDL
9a	30 sec. draw	5:37	"	"		BDL
10	First Flush	5:39	Hallway nr. G701	"		1.6

10a	30 sec. draw	5:39	"	"		1.8
11	First Flush	5:43	Hallway nr. G704	"		BDL
11a	30 sec. draw	5:44	"	"		BDL
12	First Flush	5:47	Sink in Trainer's Rm.	"		BDL
12a	30 sec. draw	5:48	"	"		BDL
13	First Flush	5:51	Hose Trnr	"		2.8
13a	30 sec. draw	5:52	"	"		BDL
14	First Flush	5:53	Ice Maker	"		BDL
14a	30 sec. draw	5:54	"	"		BDL
15	First Flush	5:55	Hallway nr. G4120	"		4.7
15a	30 sec. draw	5:56	"	"		1.6
16	First Flush	5:58	Hallway nr. G418	"		BDL
16a	30 sec. draw	5:59	"	"		BDL
17	First Flush	6:00	Hallway nr. G411	"		BDL
17a	30 sec. draw	6:01	"	"		2.5
18	First Flush	6:03	Hallway nr. G4120	"		1.2
18a	30 sec. draw	6:04	"	"		BDL
19	First Flush	6:06		"		1.1
19a	30 sec. draw	6:07		"		BDL
20	First Flush	6:10		"		1.3
20a	30 sec. draw	6:11		"		1.9

### Drinking water Sampling and Analysis for Lead (Pb)

Page 2 of 2

Sample No	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
21	First Flush	6:13	Sink in G1105	KC		BDL
21a	30 sec. draw	6:14	"	"		BDL
22	First Flush	6:17	Sink in 1106	KC	<b>Highest</b>	<b>12.0</b>
22a	30 sec. draw	6:18	"	"		3.9
23	First Flush	6:20	Hallway nr. 1406	"		4.5
23a	30 sec. draw	6:21	"	"		1.3
24	First Flush	6:23	N sink in 1418	KC		3.7
24a	30 sec. draw	6:24	"	"		3.8

25	First Flush	6:25	Sink nr. Door in 1418	KC		1.3
25a	30 sec. draw	6:26	"	"		1.4
26	First Flush	6:28	Sink in 1420	KC		BDL
26a	30 sec. draw	6:29	"	"		BDL
27	First Flush	6:31	Outside 1415A	"		BDL
27a	30 sec. draw	6:32	"	"		BDL
28	First Flush	6:33	Outside 1624	"		4.2
28a	30 sec. draw	6:34	"	"		3.5
29	First Flush	6:36	Outside 1322	"		2.2
29a	30 sec. draw	6:37	"	"		BDL
30	First Flush	6:41	Outside 1205	"		6.0
30a	30 sec. draw	6:42	"	"		BDL
31	First Flush	6:43	Outside 1231	"		7.6
31a	30 sec. draw	6:44	"	"		BDL
32	First Flush	6:48	In Aud. Hall	"		BDL
32a	30 sec. draw	6:49	"	"		BDL
33	First Flush	6:51		"		BDL
33a	30 sec. draw	6:52	"	"		BDL