

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Building Name: MacNamara Elementary School

Total No. Samples: 46

Sample No.	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
1	First Flush		Kitchen - N wall	KC	Highest	6.8
1a	30 sec. draw		"	"		2.9
2	First Flush		Cafeteria	DF	ceramic	5.5
2a	30 sec. draw		"	"	"	1.5
3	First Flush		C-Link Left	"		4.3
3a	30 sec. draw		"	"		2.3
4	First Flush		C-Link Right	"		5.8
4a	30 sec. draw		"	"		2.4
5	First Flush		C101	"		BDL
5a	30 sec. draw		"	DF		BDL
6	First Flush		C103	"		BDL
6a	30 sec. draw		"	"		BDL
7	First Flush		C105	"		BDL
7a	30 sec. draw		"	"		BDL
8	First Flush		C107	"		4.4
8a	30 sec. draw		"	"		BDL
9	First Flush		C111	DF		4.1
9a	30 sec. draw		"	"		2.2
10	First Flush		C110	"		3.1
10a	30 sec. draw		"	"		1.2
11	First Flush		C108	"		2.4
11a	30 sec. draw		"	"		BDL
12	First Flush		C106	DF		4.0
12a	30 sec. draw		"	"		BDL
13	First Flush		C104	"		2.0
13a	30 sec. draw		"	"		1.0
14	First Flush		C102	"		2.2
14a	30 sec. draw		"	"		BDL
15	First Flush		B Wing hall -Left	"	ceramic	1.4
15a	30 sec. draw		"	"	"	BDL
16	First Flush		B Wing hall - Rt.	DF	ceramic	1.8
16a	30 sec. draw		"	"	"	BDL
17	First Flush		B215	"		BDL
17a	30 sec. draw		"	"		BDL
18	First Flush		B216	"		BDL
18a	30 sec. draw		"	"		BDL
19	First Flush		B116	DF		BDL
19a	30 sec. draw		"	"		BDL
20	First Flush		B115	"		BDL
20a	30 sec. draw		"	"		BDL

Drinking water Sampling and Analysis for Lead (Pb)

Sample No.	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	(if DF - model No.)	Lead Conc. (ppb)
21	First Flush		B111	DF		5.0
21a	30 sec. draw		B111	DF		1.6
22	First Flush		Lower B Hall - Left	DF	Ceramic	1.2
22a	30 sec. draw		"	DF	"	BDL
23	First Flush		Staff Lounge	KC - composite		BDL
23a	30 sec. draw	>>>>>>>>>>	>>>>>>>>>>	>>>>>>>>>>	>>>>>>>>	>>>>>>>>: