

## Drinking water Sampling and Analysis for Lead (Pb)

Building Name: Reynolds Elementary School

Total No. Samples: **56**      BDL = Below Detection Limits

[Does not mean the sample is lead-free]

Sample No	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
1	First Flush	7:15 AM	Kitchen	KC		6.3
1a	30 sec. draw	7:16 AM	"	"		BDL
2	First Flush	7:17 AM	Cafeteria	WC		1.4
2a	30 sec. draw	7:18 AM	"	"		1.3
3	First Flush	7:19 AM	Hall acr. Faculty	WC		<b>BDL</b>
3a	30 sec. draw	7:19 AM	"	WC		BDL
4	First Flush	7:25 AM	Staff Lounge	KC		BDL
4a	30 sec. draw	7:25 AM	"	"		BDL
5	First Flush	7:30 AM	Nurse's Office	NS		1
5a	30 sec. draw	7:30 AM	"	"		BDL
6	First Flush	7:31 AM	Copy Room	KC		6.8
6a	30 sec. draw	7:31 AM	"	"		BDL
7	First Flush	7:33 AM	Hall nr. 110	WC	Left	BDL
7a	30 sec. draw	7:33 AM	Hall nr. 110	WC	Left	BDL
8	First Flush	7:37 AM	Hall nr. 110	WC	Right	BDL
8a	30 sec. draw	7:37 AM	Hall nr. 110	WC	Right	BDL
9	First Flush	7:40 AM	Room 114	DF		<b>33</b>
9a	30 sec. draw	7:40 AM	"	DF		8
10	First Flush	7:41 AM	Hall nr. 118	WC	Left	BDL
10a	30 sec. draw	7:41 AM	Hall nr. 118	WC	Left	BDL
11	First Flush	7:49 AM	Hall nr. 118	DF	Right	BDL
11a	30 sec. draw	7:50 AM	Hall nr. 118	DF	Right	BDL
12	First Flush	7:51 AM	Room 113	DF		3.0
12a	30 sec. draw	7:51 AM	"	DF		1.2
13	First Flush	7:52 AM	Room 128	KC		12
13a	30 sec. draw	7:52 AM	"	KC		1.7
14	First Flush	7:53 AM	Room 130	DF		13
14a	30 sec. draw	7:53 AM	"	DF		BDL
15	First Flush	7:54 AM	Room 134	DF		12
15a	30 sec. draw	7:54 AM	"	DF		2.9
16	First Flush	7:56 AM	Room 123	DF		16
16a	30 sec. draw	7:56 AM	"	DF		1.5
17	First Flush	7:58 AM	Room 136	DF		1.1
17a	30 sec. draw	7:58 AM	"	DF		BDL
18	First Flush	8:00 AM	Room 125	DF		5.2
18a	30 sec. draw	8:00 AM	"	DF		BDL
19	First Flush	8:03 AM	Room 138	DF		BDL
19a	30 sec. draw	8:03 AM	"	DF		BDL

20	First Flush	8:06 AM	Room 127	DF		4.3
20a	30 sec. draw	8:06 AM	"	DF		BDL

**Drinking water Sampling and Analysis for Lead (Pb)**

Sample No	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	(if DF -model No.)	Lead Conc. (ppb)
21	First Flush	8:08 AM	Room 140	DF		10
21a	30 sec. draw	8:08 AM	"	DF		2.1
22	First Flush	8:10 AM	Room 129	DF		3.1
22a	30 sec. draw	8:10 AM	"	DF		BDL
23	First Flush	8:12 AM	Room 142	DF		10
23a	30 sec. draw	8:12 AM	"	DF		2.6
24	First Flush	8:14 AM	Room 144	DF		9.9
24a	30 sec. draw	8:14 AM	"	DF		1.9
25	First Flush	8:16 AM	Room 146	DF		11
25a	30 sec. draw	8:16 AM	"	DF		2.5
26	First Flush	8:18 AM	Room 148	DF		8.9
26a	30 sec. draw	8:18 AM	"	DF		2
27	First Flush	8:20 AM	Room 150	DF		10
27a	30 sec. draw	8:20 AM	"	DF		2.4
28	First Flush	8:21 AM	Hall nr. 148	WC	Halsey T	2
28a	30 sec. draw	8:21 AM	"	WC		3.3
29	First Flush	<<<<<<<<	<<<<<<<,	>>>>>>>>	>>>>>>>>	>>>>>>
29a	30 sec. draw					
30	First Flush					
30a	30 sec. draw					
31	First Flush					
31a	30 sec. draw					
32	First Flush					
32a	30 sec. draw					