

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Building Name: Van Buren Elementary School

Total No. Samples: 44

Sample No	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
1	First Flush	3/18/16 - 6:08	Room 101	KC		5.8
1a	30 sec. draw	6:08	"	"		1.1
2	First Flush	6:10	Room 102	DF	ceramic	9.7
2a	30 sec. draw	6:10	"	"	"	1.5
3	First Flush	6:12	Room 103	"	highest	13.0
3a	30 sec. draw	6:13	"	"		2.0
4	First Flush	6:15	Room 109	"		4.9
4a	30 sec. draw	6:16	"	"		1.1
5	First Flush	6:18	Hallway nr. 109	"	Left side	BDL
5a	30 sec. draw	6:19	"	DF	"	BDL
6	First Flush	6:20	Hallway nr. 109	"	Right Side	BDL
6a	30 sec. draw	6:21		"	"	BDL
7	First Flush	6:23	Room 111B	"		3.8
7a	30 sec. draw	6:24	"	"		BDL
8	First Flush	6:26	Room 118	"		4.1
8a	30 sec. draw	6:27	"	"		BDL
9	First Flush	6:29	122 - Café	DF		BDL
9a	30 sec. draw	6:30	"	"		1.4
10	First Flush	6:32	Room 115	KC	sink	11
10a	30 sec. draw	6:33	"	"	"	1.3
11	First Flush	6:34	Room 119	"		1.6
11a	30 sec. draw	6:35	"	"		2.2
12	First Flush	6:36	Room 123	DF		1.5
12a	30 sec. draw	6:37	"	"		2.2
13	First Flush	6:39	Room 128	"		2.3
13a	30 sec. draw	6:40	"	"		1.7

14	First Flush	6:42	Hall nr. 141A	DF	Left side	BDL
14a	30 sec. draw	6:43	"	"	Left side	BDL
15	First Flush	6:45	Hall nr. 141A	"	Right Side	0.3
15a	30 sec. draw	6:46	"	"	Right Side	BDL
16	First Flush	6:47	Room 141B	DF		4.0
16a	30 sec. draw	6:49	"	"	"	BDL
17	First Flush	6:50	Room 145	"		3.4
17a	30 sec. draw	6:51	"	"		BDL
18	First Flush	6:52	Room 147	"		8.4
18a	30 sec. draw	6:52	"	"		2.6
19	First Flush	6:53	Room 150	DF		5.4
19a	30 sec. draw	6:54		"		1.9
20	First Flush	6:56	Room 151	"		BDL
20a	30 sec. draw	6:57	"	"		BDL

Drinking water Sampling and Analysis for Lead (Pb)

Page 2 of 2

Sample No	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	(if DF -model No.)	Lead Conc. (ppb)
21	First Flush	6:58	Room 152	DF		BDL
21a	30 sec. draw	6:59	"	DF		BDL
22	First Flush	7:01	Room 153	DF		1.0
22a	30 sec. draw	3/18/16-7:02	"	DF	"	BDL
23	First Flush	>>>>>>>>>>	>>>>>>>>>>>>	>>>>>>>>>>>>	>>>>>>>>>>>>	>>>>>>>>>>>>
23a	30 sec. draw					
24	First Flush					
24a	30 sec. draw					
25	First Flush					
25a	30 sec. draw					
26	First Flush					
26a	30 sec. draw					
27	First Flush					
27a	30 sec. draw					
28	First Flush					
28a	30 sec. draw					
29	First Flush					
29a	30 sec. draw					
30	First Flush					
30a	30 sec. draw					
31	First Flush					
31a	30 sec. draw					
32	First Flush					
32a	30 sec. draw					

