

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BR = bathroom sink

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 10/27/2016

Building Name: Durgee Jr. High School

Total No. Samples: 50

Sample No.	Description	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Retest - Lead Conc. (ppb)
DJH1	First Draw	5:05 AM	Rm 121	Sink - A	Faculty BR	4.6	
DJH2	First Draw	5:05 AM	Rm 121	Sink - B	Faculty BR	5.9	
DJH3	First Draw	5:05 AM	Rm 121	Sink - C	Faculty BR	11.0	
DJH4	First Draw	5:13 AM	Rm 124	Sink - A	Girls BR Sink	11.0	
DJH5	First Draw	5:13 AM	Rm 124	Sink - B	Girls BR Sink	12.0	
DJH6	First Draw	5:13 AM	Rm 124	Sink - C	Girls BR Sink	8.0	
DJH7	First Draw	5:15 AM	Rm 116	Sink - A	Girls BR Sink	8.3	
DJH8	First Draw	5:15 AM	Rm 116	Sink - B	Girls BR Sink	8.8	
DJH9	First Draw	5:15 AM	Rm 116	Sink - C	Girls BR Sink	10.0	
DJH10	First Draw	5:15 AM	Rm 116	Sink - D	Girls BR Sink	9.2	
DJH11	First Draw	5:15 AM	Rm 116	Sink - E	Girls BR Sink	16.0	2.9
DJH12	First Draw	5:15 AM	Rm 116	Sink - F	Girls BR Sink	12.0	
DJH13	First Draw	5:19 AM	Rm 117	Sink - A	Boys BR Sink	3.0	
DJH14	First Draw	5:19 AM	Rm 117	Sink - B	Boys BR Sink	4.6	
DJH15	First Draw	5:19 AM	Rm 117	Sink - C	Boys BR Sink	4.1	
DJH16	First Draw	5:19 AM	Rm 117	Sink - D	Boys BR Sink	14.0	
DJH17	First Draw	5:19 AM	Rm 117	Sink - E	Boys BR Sink	1.9	
DJH18	First Draw	5:25 AM	Rm 510	Sink	Womens BR	4.8	
DJH19	First Draw	5:26 AM	Rm 306	Sink - A	Boys BR Sink	2.4	
DJH20	First Draw	5:26 AM	Rm 306	Sink - B	Boys BR Sink	3.8	
DJH21	First Draw	5:26 AM	Rm 306	Sink - C	Boys BR Sink	2.4	
DJH22	First Draw	5:26 AM	Rm 306	Sink - D	Boys BR Sink	3.0	
DJH23	First Draw	5:26 AM	Rm 306	Sink - E	Boys BR Sink	1.2	
DJH24	First Draw	5:30 AM	Rm 515	Sink - A	Girls BR Sink	4.8	
DJH25	First Draw	5:30 AM	Rm 515	Sink - B	Girls BR Sink	5.7	
DJH26	First Draw	5:30 AM	Rm 515	Sink - C	Girls BR Sink	4.6	
DJH27	First Draw	5:30 AM	Rm 515	Sink - D	Girls BR Sink	4.0	

DJH28	First Draw	5:30 AM	Rm 515	Sink - E	Girls BR Sink	3.9	
DJH29	First Draw	5:35 AM	Rm 153	Sink -A	Girls BR Sink	5.2	
DJH30	First Draw	5:35 AM	Rm 153	Sink - B	Girls BR Sink	2.7	
DJH31	First Draw	5:35 AM	Rm 153	Sink - C	Girls BR Sink	4.6	
DJH32	First Draw	5:37 AM	Rm 150	Sink -A	Boys BR Sink	4.6	
DJH33	First Draw	5:37 AM	Rm 150	Sink - B	Boys BR Sink	2.3	
DJH34	First Draw	5:37 AM	Rm 150	Sink - C	Boys BR Sink	3.1	
DJH35	First Draw	5:40 AM	Near Door 11	Spigot		9.1	
DJH36	First Draw	5:42 AM	Near Rm 123	Spigot		<1.0	
DJH37	First Draw	5:44 AM	Rm 149	CF		3.5	
DJH38	First Draw	5:45 AM	Rm 147	Sink	L. Window	11.0	
DJH39	First Draw	5:45 AM	Rm 147	Sink	R. Window	16.0	10.0
DJH40	First Draw	5:45 AM	Rm 147	Sink	L. Hall	15.0	
DJH41	First Draw	5:45 AM	Rm 147	Sink	R. Hall	3.8	
DJH42	First Draw	5:50 AM	Boys Locker RM	Sink -A		<1.0	
DJH43	First Draw	5:50 AM	Boys Locker RM	Sink - B		1.8	
DJH44	First Draw	5:50 AM	Boys Locker RM	Sink - C		1.9	
DJH45	First Draw	5:51 AM	Near Library	DF	Bottle Fill	1.6	
DJH46	First Draw	5:51 AM	Near Library	DF	Fountain	1.7	
DJH47	First Draw	5:54 AM	Girls Locker RM	Sink -A		1.4	
DJH48	First Draw	5:54 AM	Girls Locker RM	Sink - B		3.0	
DJH49	First Draw	5:54 AM	Girls Locker RM	Sink - C		8.3	
DJH50	First Draw	5:54 AM	Girls Locker RM	Sink - D		3.1	
DURext410a	First Draw	6:39am	Outside Spigot 410	Spigot	Jan 13 2017	1.0	