

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 3/24/2016

Building Name: Elden Elementary School

Total No. Samples: 46 1 sample spilled

Sample No.	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Retest Results [Pb] (ppb)
1	First Flush	3/24 -5:33	Kitchen	KC	Kitchen	3.3	
1a	30 sec. draw	5:34	"	"	"	BDL	
2	First Flush	5:35	Hall nr. 111 -L	DF	dbl. unit	BDL	
2a	30 sec. draw	5:36	"	"	"	BDL	
3	First Flush	5:38	Hall nr. 111 -R	"	"	BDL	
3a	30 sec. draw	5:39	"	"	"	BDL	
4	First Flush	5:40	Rm. 101	"		2.0	
4a	30 sec. draw	5:41	"	"		BDL	
5	First Flush	5:42	Rm. 102	"		2.5	
5a	30 sec. draw	5:43	"	DF		BDL	
6	First Flush	5:43	Room 103	"	stainless	1.6	
6a	30 sec. draw	5:44	"	"	"	BDL	
7	First Flush	5:46	Room 104	"		1.8	
7a	30 sec. draw	5:47	"	"		BDL	
8	First Flush	5:48	Room 106	"		BDL	
8a	30 sec. draw	5:49	"	"		BDL	
9	First Flush	5:50	Room 107	DF		6.8	
9a	30 sec. draw	5:51	"	"		1.7	
10	First Flush	5:52	Room 108	"		1.2	
10a	30 sec. draw	5:52	"	"		BDL	
11	First Flush	5:55	Staff Lounge	KC		2.6	
11a	30 sec. draw	5:56	"	KC	"	BDL	
12	First Flush	5:57	Hall nr. 121	DF		5.0	
12a	30 sec. draw	5:58	"	"		2.6	
13	First Flush	6:00	Hall nr. 123	"		41.0	12 - (1/13/17)
13a	30 sec. draw	3/24 - 06:02	"	"		4.1	
14	First Flush	3/24 -06:03	Hall nr. 126	"		20.0	Removed from service
14a	30 sec. draw	6:03	"	"		3.4	

