

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BR = bathroom sink

SP = Spigot

Cof - Coffee pot supply

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 9/21/2017

Building Name: Concession Building

Total No. Samples: 30

Sample No.	Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)	Retest - Nov 3, 2017 Lead Conc. (ppb)
170921-1	8:07am	Lower Boys Bathroom	Sink A		8.8	
170921-2	8:07am	Lower Boys Bathroom	SinkB		6.6	
170921-3	8:08am	Lower Boys Bathroom	Sink C		5.1	
170921-4	8:08am	Lower Boys Bathroom	Sink D		11.0	
170921-5	8:18am	Lower Drinking Fountain	DF -left		1.0	
170921-6	8:18am	Lower Drinking Fountain	DF- Right		1.0	
170921-7						
170921-8	8:21am	Lower Girls Bathroom	Sink A		9.5	
170921-9	8:22am	Lower Girls Bathroom	Sink B		8.7	
170921-10	8:22am	Lower Girls Bathroom	SinkD		6.2	
170921-11	8:37am	Lower Kitchen Coffee	Cof		17.0	
170921-12	8:40am	Lower prep Sink	KC		1.1	
170921-13	8:43am	Lower Hand Sink	KC		6.4	
170921-14	8:44am	Lower 3 Bay Sink	KC		3.9	
170921-15	8:53am	HW Sink North	KC		8.1	
170921-16	9:03am	Ice Machine			3.8	
170921-17	9:08am	Upper Girls Bathroom	Sink 3		80.0	
170921-18	9:09am	Upper Kitchen HW sink	KC		20.0	
170921-19	9:10am	Upper Kitchen Sink	KC		17.0	
170921-21	9:13am	Upper Girls bathroom	Sink A		20.0	
170921-22	9:14am	Upper Girls Bathroom	Sink B		20.0	
170921-23	9:48am	Upper Girls Bathroom	Sink C		20.0	
170921-24	9:48am	Upper Girls Bathroom	Sink D		50.0	
170921-25	9:50am	Upper Drinking Fountian	DF-Right		1.0	

170921-26	9:52am	Upper Drinking Fountian	DF-Left		1.0	
170921-27	9:54am	Upper Boys Bathroom	Sink A		12.0	
170921-28	9:52am	Upper Boys Bathroom	Sink B		17.0	
170921-29	9:54am	Upper Boys Bathroom	Sink C		17.0	
170921-30	9:56am	Old Conc Drink Ftn	DF		1.0	
170921-31	9:57 AM	Upper Boys Bathroom	Sink D		2.5	