

Drinking water Sampling and Analysis for Lead (Pb)

Codes for sampling points.

WC = water cooler (chiller unit)

CF = classroom faucet

KC = kitchen faucet, cold

EC = home economics room, cold

EH = home economics room sink, hot

NS = nurse's office sink

SC = service connector

BR = bathroom sink

LR = Locker Room

DF = Drinking Fountain

BDL = Below Detection Limits

[Does not mean the sample is lead-free]

School District Name: Baldwinsville CSD

Date: 9/28/2016

Building Name: McNamara

Total No. Samples: 46

Sample No.	Description	Date/Time Sampled	Location of Water Outlet	Type of Outlet (i.e. sink, DF)	Notes	Lead Conc. (ppb)
McNamara-1	First Draw	5:39 AM	A112 - BR	Sink A		3.1
McNamara-2	First Draw	5:39 AM	A112 - BR	Sink B		7.5
McNamara-3	First Draw	5:40 AM	A111 - BR	Sink A		6.1
McNamara-4	First Draw	5:40 AM	A111 - BR	Sink B		3.6
McNamara-5	First Draw	5:43 AM	C102	CF		1.7
McNamara-6	First Draw	5:44 AM	C104	CF		3.2
McNamara-7	First Draw	5:45 AM	C106	CF		2.7
McNamara-8	First Draw	5:46 AM	C108	CF		3.4
McNamara-9	First Draw	5:47 AM	C110	CF		3.5
McNamara-10	First Draw	5:47 AM	C111	CF		4.0
McNamara-11	First Draw	5:47 AM	C111	BR		4.3
McNamara-12	First Draw	5:49 AM	C107	CF		2.7
McNamara-13	First Draw	5:49 AM	C107	BR		3.3
McNamara-14	First Draw	5:50 AM	C105	CF		1.9
McNamara-15	First Draw	5:51 AM	C103	CF		1.9
McNamara-16	First Draw	5:52 AM	C101	CF		1.7
McNamara-17	First Draw	5:54 AM	BR - B WING	Sink A		<1.0
McNamara-18	First Draw	5:54 AM	BR - B WING	Sink B		<1.0
McNamara-19	First Draw	5:56 AM	BR - B WING	Sink A		<1.0
McNamara-20	First Draw	5:56 AM	BR - B WING	Sink B		9.8
McNamara-21	First Draw	5:56 AM	BR - B WING	Sink C		<1.0
McNamara-22	First Draw	5:59 AM	B104	BR		7.8
McNamara-23	First Draw	6:00 AM	B107	CF		14.0
McNamara-24	First Draw	6:00 AM	B106	CF		6.1

McNamara-25	First Draw	6:01 AM	B109	CF		4.2
McNamara-26	First Draw	6:02 AM	B108	CF		5.2
McNamara-27	First Draw	6:02 AM	B111	CF		13.0
McNamara-28	First Draw	6:03 AM	B110	CF		7.4
McNamara-29	First Draw	6:04 AM	B113	CF		3.9
McNamara-30	First Draw	6:04 AM	B112	CF		8.5
McNamara-31	First Draw	6:05 AM	B115	CF		2.2
McNamara-32	First Draw	6:06 AM	B116	CF		12.0
McNamara-33	First Draw	6:08 AM	B215	CF		3.0
McNamara-34	First Draw	6:09 AM	B216	CF		<1.0
McNamara-35	First Draw	6:10 AM	B212	CF	Library Office	2.3
McNamara-36	First Draw	6:11 AM	B213	CF		11.0
McNamara-37	First Draw	6:12 AM	B211	CF		9.8
McNamara-38	First Draw	6:12 AM	B209	CF		6.9
McNamara-39	First Draw	6:13 AM	B207	CF		3.7
McNamara-40	First Draw	6:14 AM	B202	BF	STAFF LAV	4.1
McNamara-41	First Draw	6:15 AM	B205	SINK A		6.0
McNamara-42	First Draw	6:15 AM	B205	SINK B		1.2
McNamara-43	First Draw	6:18 AM	B201	SINK A		1.5
McNamara-44	First Draw	6:18 AM	B201	SINK B		<1.0
McNamara-45	First Draw	6:18 AM	B201	SINK C		<1.0
McNamara-46	First Draw	6:21 AM	MAIN OFFICE	BF		4.7